



Certificate of constancy of performance

0099/CPR/B85/0070

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

INDUSTRIAS PEVI, S.A.

registered office	CL SANTA CRUZ, S/N 31700 ELVETEA-ELIZONDO (Navarra - Spain)
Certified performance	Reaction to Fire of power electric cables for general applications in construction Works.
Harmonised Standard	EN 50575:2014 EN 50575:2014/A1:2016
Designation	H07Z1-K Type 2 (AS)
Trade Mark	PEVI
Reaction to Fire Class	Cca-s1b,d1,a1
Cross-sectional Range	1x1,5 mm ² ; 1x2,5 mm ² ; 1x4 mm ² ; 1x6 mm ² ; 1x10 mm ² ; 1x16 mm ² ; 1x25 mm ² ; 1x35 mm ² ; 1x50 mm ² ; 1x70 mm ² ; 1x95 mm ² ; 1x120 mm ² .
Rated Voltage	450/750 V
Generic Power Cable Family	Single core unsheathed
Production site	CL SANTA CRUZ, S/N 31700 ELVETEA-ELIZONDO (Navarra - Spain)
Certification scheme	This certificate attests that all provisions under system 1+ concerning the assessment and verification of performance of the declared reaction to fire and its constancy described in Annex ZZ of the harmonised standard are applied. This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.
First issued on	2017-05-23
Last issued on	2026-05-23
Validity	2029-05-23

Rafael GARCÍA MEIRO
CEO

