



Certificate of constancy of performance

0099/CPR/B85/0109

In compliance with Construction Products Regulation 305/2011/EU of the European Parliament and of the Council, of 9 March 2011, the notified body AENOR (n. 0099) has issued this certificate to

INDUSTRIAS PEVI, S.A.

registered office CL SANTA CRUZ, S/N
31700 ELVETEA-ELIZONDO (Navarra - Spain)

Certified performance **Reaction to Fire of power electric cables for general applications in construction Works.**

Harmonised Standard EN 50575:2014
EN 50575:2014/A1:2016

Designation ES05Z1-K (AS)
Trade Mark PEVI
Reaction to Fire Class Cca-s1b,d1,a1
Cross-sectional Range 1x0,5 mm²; 1x0,75 mm²; 1x1 mm²
Rated Voltage 300/500 V
Generic Power Cable Family Single core unsheathed

Production site CL SANTA CRUZ, S/N
31700 ELVETEA-ELIZONDO (Navarra - Spain)

Certification scheme This certificate attests that all provisions under system 1+ concerning the assessment and verification of performance of the declared reaction to fire and its constancy described in Annex ZZ of the harmonised standard are applied.
This certificate will remain valid until its validity date, provided that the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

First issued on 2017-06-27
Last issued on 2023-06-27
Validity 2026-06-27

Rafael GARCÍA MEIRO
CEO



AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com